

Reverse Osmosis Contaminant Removal List:

Giardia cysts	100%	Criptosporidium cysts	100%	DDT	>99.9%	PCB	>99.9%
E.coli bacteria	>99.9%	Fecal bacteria	>99.9%	Lindane	>99.9%	Salmonella typhi	>99.9%
Vibrio cholerae	>99.9%	Shigella disinteriae	>99.9%	Serratia marcescenes	>99.9%	Toluane	>99.9%
Sodium Fluoride	99%	Calcium Chloride	99%	Sodium Chloride NaCl	99%	Sucrose	99%
Magnesium Chloride	99%	Nickel Sulfate NiSO4	>99%	Copper Sulfate CuSO4	>99%	Lactic Acid pH5	99%
Glucose	98%	Sodium Nitrate NaNO3	97-99%	Chlorinated Pesticides	99.9%	Silica SiO2	98%
Sodium	95-99%	Nickel	95-99%	Chloride	99.9%	Radioactivity	95-99%
Potassium	92-99%	Zinc	95-99%	Bicarbonate	99%	Sulfate	95-99%
Calcium	95-99%	Strontium	95-99%	Nitrate 3	90-99%	Ferro cyanide	96-99%
Magnesium	95-99%	Cadmium	95-99%	Fluoride	90-95%	Arsenic +3	95-99%
Iron	95-99%	Silver	95-99%	Silicate	95-99%	Arsenic +5	95-99%
Aluminum	95-99%	Mercury	95-99%	Phosphate	95-99%	Lead	95-99%
Ammonium	95-99%	Barium	95-99%	Chromate	95-99%	Copper	95-99%